



## Technical Report


### Recycle Content of Fi-Foil Products During the Fourth Quarter of 2016

Prepared For:

Mr. Doug Kinninger  
Fi-Foil Company, Inc.  
P.O. Box 800  
612 Bridgers Ave. West  
Auburndale, FL 33823

R & D Services, Inc.  
P.O. Box 2400  
Cookeville, Tennessee 38502-2400

Report: RD17033

  
Stuart Ruis  
President

January 17, 2017

The test results in this report apply only to the specimens tested. The tests conform to the respective test methods except for the report requirements. The report includes summary data but a full complement of data is available upon request. This report shall not be reproduced, except in full, without written approval of R & D Services, Inc. This report must not be used by the client to claim product endorsement by R & D Services, Inc., IAS or any other organization.

---



P.O. Box 2400  
Cookeville, Tennessee 38502-2400  
Phone: 931-372-8871  
Fax: 931-525-3896

**Verification of Recycle Content for Reflective Insulation and Radiant  
Barrier Products Manufactured by Fi-Foil Company**

The pre-consumer and post-consumer recycled material content of the following Fi-Foil Company products has been verified for the period October 1 to December 31, 2016 by R&D Services, Inc., a third-party testing and inspection service operating in compliance with ISO 17025 (TL-566) and ISO 17020 (AA-712).

**Verified Products**

AA-2	width 16 inches	(AA-2 Vapor Shield)
AA-2	width 24 inches	(AA-2 Vapor Shield)
VR+	width 16 inches	(VR Plus Shield)
VR+	width 24 inches	(VR Plus Shield)
B-3	width 16 inches	(Silver Shield Radiant Barrier)
B-3	width 24 inches	(Silver Shield Radiant Barrier)
B-3	width 30 inches	(Silver Shield Radiant Barrier)
HYFi	width 16 inches	(Hybrid component)
HYFi	width 24 inches	(Hybrid component)

The verified weight % pre-consumer and post-consumer recycle contents for each of the above nine products are listed in Attachment 1. The product verifications are based on the recycle content of the components used to produce each product and the confirmation of a balance between incoming materials and manufactured items. Manufacturing and inventory data for the compliance period were provided by Fi-Foil Company on January 13, 2017. The most recent on-site review was completed on October 21, 2016.

A handwritten signature in black ink that reads 'David W. Yarbrough'.

David W. Yarbrough, PhD, Florida PE 0050959  
January 17, 2017



P.O. Box 2400  
 Cookeville, Tennessee 38502-2400  
 Phone: 931-372-8871  
 Fax: 931-525-3896

**Verification of Recycle Content for Reflective Insulation and Radiant  
 Barrier Products Manufactured by Fi-Foil Company 2016 Q4**

Attachment 1. Pre-Consumer and Post-Consumer Recycle Content

Product		Weight %		
		<u>Pre-Consumer</u>	<u>Post-Consumer</u>	<u>Total</u>
AA-2 Vapor Shield	width 16 inches	5.6	44.8	50.4
AA-2 Vapor Shield	width 24 inches	6.5	39.2	45.7
VR Plus Shield	width 16 inches	3.1	31.7	34.7
VR Plus Shield	width 24 inches	3.4	24.7	28.1
B-3 Silver Shield RB	width 16 inches	2.4	22.6	25.1
B-3 Silver Shield RB	width 24 inches	2.9	17.3	20.1
B-3 Silver Shield RB	width 30 inches	5.1	15.3	20.4
HYFi	width 16 inches	4.5	40.2	44.7
HYFi	width 24 inches	4.9	34.2	39.2